

TEST REPORT

SABS

Naturezone
Attention: Peter Foulis
 P O Box 10
 LIONRIVER
 3260

FOOD & WATER CHEMISTRY

Your ref: Paid(RU 236647)
 Dated: 2009-12-09
 Our ref: 262325
 Enquiries: CM Fouché
 ☎ (012) 428-6844
 Date: 2010-01-19
Report No: 2414/CW4664R1
 Page: 1 of 1

Amended Report WATER SAMPLE RESULTS OF ANALYSIS

Date received: 2009-12-09

Date commenced: 2009-12-09

| Method used | Test performed | P1334 Water Sample |
|---|---|-----------------------|
| T0319 - 5,4 - OIB | pH at 25 °C (automated) | 8,0 |
| | Conductivity at 25 °C in mS/m (automated) | 16,7 |
| SANS 11885:2008 & T0319-5.4-01A | Calcium as Ca in mg/ℓ | 15,6 |
| | Magnesium as Mg in mg/ℓ | 7,6 |
| | Sodium as Na in mg/ℓ | 7,5 |
| | Potassium as K in mg/ℓ | 1,1 |
| SANS 11885:2008 & T0319-5.4-01A | Iron as Fe in mg/ℓ | 0,08 |
| | Manganese as Mn in mg/ℓ | <0,05 |
| SANS 5213:2005 | Dissolved solids at 180 °C in mg/ℓ | 104 |
| SANS10359-1:2002 | Fluoride as F in mg/ℓ | 0,2 |
| T0319 - 5,4 - OIB | Total alkalinity as CaCO ₃ in mg/ℓ (automated) | 81 |
| Microbiological Characteristics | | |
| SANS 5221:2007(Ed 4.3) & F.M 5.4 W-B [SANAS Sub-Contracted Lab T0269] | Total bacterial count per 1mℓ | >30 000 |



CM Fouché: Manager/ Technical Signatory



MS Mabe: Senior Test Officer
 Admin@spectrum.co.za

CONFIDENTIALITY NOTICE

This message is intended only for the use of individual or entity to which it is addressed and in terms of Section 30 of the Standards Act, 2008, it contains information that is strictly confidential. If the reader of this message is not the intended recipient, or the employee or agent responsible for delivering the message to the intended recipient, you are hereby notified that any disclosure, distribution, copying or the taking of any action in reliance on the contents of this communication, is strictly prohibited. If you have received this communication in error, please notify us immediately by telephone to arrange for the return of the documents to us.

Note: This report replaces report 2414/CW4664 dated 2009-12-22

1 Dr Lategan Road, Groenkloof, Private Bag X191, Pretoria, 0001. Tel +27 12 428 7911, Fax +27 12 344 1568

The test work relating to this report was performed by SABS Commercial (Pty) Ltd. This report and its test results relate only to the specific sample(s) identified herein. They do not imply SABS approval of the quality and/or performance of the item(s) in question and the test results do not apply to any similar item that has not been tested. (Refer also to the conditions of test printed on the back of this page.) This report may not be reproduced except in full. The authenticity of this report and its contents can be confirmed by contacting the person who signed it.

